



OFFICE OF THE DY. FIRE OFFICER,
KORAPUT CIRCLE, KORAPUT
(KORAPUT / NABARANGAPUR / MALKANGIRI / RAYAGADA)

No. 1451/ KPT CrI.

Dtd 19.04.2022

To

The Principal,
Kendriya Vidyalaya. Gunupur,
Dist- Rayagada.

Ref: - Your online application number FSC1409280032022000003 Dtd. 26.03.2022
requesting for Fire Safety Certificate.

Sub: - Regarding issuance of Fire Safety certificate in respect Kendriya Vidyalaya. Gunupur,
Dist- Rayagada.

Sir,

With reference to the subject cited above this is to intimate that, as per Rule 3(j) of Odisha Fire Prevention and Fire safety (Amendment) Rules-2019, the following Educational Buildings are only required to obtain Fire safety certificate.

1. Having height of 12 mtr and above or,
2. Having a built up area of 1000 square meters or above, or
3. Having 03 storied buildings.

However, undertaken verification by a team of Fire Service Officers on 18.04.2022, Kendriya Vidyalaya. Gunupur, Dist- Rayagada is situated over Plot No. 18, Khata No 154, Mouza- Gunupur, Dist- Rayagada contains 01 block having G+1 floors, total Built-up area= approx. 840 Sq mt and height= approx. 07 mtrs.

Hence, as per provisions of Rule 3(j) of Odisha Fire Prevention and Fire Safety (Amendment) Rules-2019, Fire Safety Certificate (F.S.C) is not required to the afore-said educational building as on date of verification i.e 18.04.2022.

However 02 Nos of ABC (06kg) & 02 Nos of 4.5 kg CO₂ Fire Extinguishers, have been installed which was found working condition during verification.

Here with your application is disposed of accordingly.

Yours faithfully


19/04/2022
Dy. Fire Officer
Deputy Fire Officer
Koraput Circle, Koraput
Koraput
Koraput